

State / Regional / District / Public Health Laboratory *Ahilyanagar*

E-mail-ID : *dphlanr@gmail.com*

Phone No. : *(0241) 2354038*

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :- *28-11-24* Date of Receipt :- *28-11-24* Date of Examination :- *28-11-24 onwards*

(All the Analytical Results are in mg./Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1) ज्ञारपत्रयत नक्त क्रमशः	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear			-	-
2.	Odour	Odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.1			1.0	5.0
4.	pH Value	7.2			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	80			250	1000
6.	Nitrates (as NO ₃)	1.0			45	No relaxation
7.	Total Hardness (as CaCO ₃)	60			200	600
8.	Alkalinity (as CaCO ₃)	52			200	600
9.	Total Dissolved Solids	190			500	2000
10.	Iron (as Fe)	0.02			0.3	No relaxation
11.	Fluoride (as F)	0.38			1.0	1.5
12.	Other Tests (if any)	—				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

* This report is restricted only for the Sample/s is Submitted to this Laboratory.

* This Samples/s is / are not Collected by this Laboratory.

(P.T.O)

REMARKS

A) Sample No. (s) 1 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) — Contains —

—
—
—
—

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) — Contains —

—
—
—
—

Hence, this / these water Sources is/ are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 2464

Date: 4-12-24

Forwarded With Compliments To: प्राचार्य

परमेश्वर इट्टेन्डेन्स एन्ड स्ट्यूडी

अकोले, ता. अकोले जि. अ. ब. एस

With reference to letter No.: परमेश्वर/49/20-24-25 Dated: 28.11.2024

Fees Rs.: 940/-

Receipt No. and Date: 4461763, 28.11.2024



B. U. Z. D. M.
Junior Scientific Officer
District Public Health Laboratory
Ahmednagar



तालुका आरोग्य अधिकारी कार्यालय
पंचायत समिती अकोले



डॉ. शामकांत वि. शेटे तालुका आरोग्य अधिकारी आरोग्य विभाग	फोन (०२४२४) २२२७०४	तालुका आरोग्य अधिकारी कार्यालय, पंचायत समिती अकोले Email ID- thoakole@yahoo.co.in
		जा.क्र./आरोग्य/८४५/२४ दि. १६/१२/२०२४

APPENDIX – Xiii

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 16/12/2024

It is certified that an inspection team headed by Dr. S.V Shete (Name of Officers with designation) from Taluka Health Officer, Panchayat Samiti, Akole Tal. Akole (Name of Department/ Office) inspected the Perfect International School, Tal. Akole Dist. Ahmednagar , Maharashtra. (Name & Address of the school) on 13/12/2024 (date of inspection) and found that the Perfect International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of 6 Months.

Signature with Seal:

Name: (Dr. Shamkant Shete)

Designation: Taluka Health Officer

Name & Address of the Office / Department: Panchayat Samiti Akole

To

Akole Taluka Education Society's,
Perfect International School,
Akole, Tal. Akole , Dist Ahmednagar,
Maharashtra.
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.